



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

SHELLY EDGERTON
DIRECTOR

December 2, 2016

Renee Reynolds
Mulberry Senior Residence, LLC
18854 Parke East Ct.
Riverview, MI 48193

RE: License #: AS820382528
Mulberry Senior Residence
17928 Mulberry
Riverview, MI 48193

Dear Ms. Reynolds:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (313) 456-0380.

Sincerely,

A handwritten signature in blue ink that reads "Pandrea Robinson".

Pandrea Robinson, Licensing Consultant
Bureau of Community and Health Systems
Cadillac Pl. Ste. 9-100
3026 W. Grand Blvd
Detroit, MI 48202
(313) 319-9682

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	AS820382528
Licensee Name:	Mulberry Senior Residence, LLC
Licensee Address:	18854 Parke East Ct. Riverview, MI 48193
Licensee Telephone #:	(734) 250-1812
Administrator/Licensee Designee:	Renee Reynolds
Name of Facility:	Mulberry Senior Residence
Facility Address:	17928 Mulberry Riverview, MI 48193
Facility Telephone #:	(734) 225-1104
Capacity:	6
Program Type:	AGED ALZHEIMERS

II. Purpose of Addendum

To add wheelchair accessibility to the license.

III. Methodology

11/11/2016	Contact- Document received Received modification request from licensee designee requesting to add wheelchair accessibility to the license.
11/30/2016	Contact-Document received Received an email from Mrs. Reynolds stating that the ramp is erected and they have obtained written approval from the city of Riverview.
12/02/2016	Measured ramp at the primary means of egress and ensured that the added wedge on the second means of egress was secure and safe. Obtained copies of the homes updated program statement and admission policy in addition to the approvals from the city of Riverview

IV. Description of Findings and Conclusions

On 12/02/16 I conducted an onsite inspection in response to the licensee designee's request to modify the license to add wheel chair accessibility. I measured the ramp at the primary means of egress. The ramp measured 1 foot 8 inches of rise and 16 feet in run. The ramp terminates on concrete and has hand rails on both open sides.

The second approved means of egress does not require a ramp as it is almost level to the ground. However, Mrs. Reynolds had a wedge installed at the entry/exit way of the door to allow for unobstructed egress when entering and exiting the home. Both ramps meet the intent of the rule and are safe. The city of Riverview approved the ramps on 11/29/16.

V. Recommendation

I recommend the license be modified to include wheelchair accessibility.

A handwritten signature in blue ink that reads "Pandrea Robinson". The signature is written in a cursive style with a large initial 'P'.

Pandrea Robinson
Licensing Consultant

12/02/16
Date