



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

SHELLY EDGERTON
DIRECTOR

July 28, 2017

Jessica Hamp
Hope Network Behavioral Health Services
PO Box 890
3075 Orchard Vista Drive
Grand Rapids, MI 49518-0890

RE: License #: AS700365883
Harbor Point Intensive - North Unit
Upper Level
16908 130th St.
Nunica, MI 49448

Dear Ms. Hamp:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (616) 356-0100.

Sincerely,

A handwritten signature in black ink that reads "Grant Sutton".

Grant Sutton, Licensing Consultant
Bureau of Community and Health Systems
Unit 13, 7th Floor
350 Ottawa, N.W.
Grand Rapids, MI 49503
(616) 916-4437

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #: AS700365883

Licensee Name: Hope Network Behavioral Health Services

Licensee Address: PO Box 890
3075 Orchard Vista Drive
Grand Rapids, MI 49518-0890

Licensee Telephone #: (616) 726-1998

Administrator/Licensee Designee: Jessica Hamp, Designee
Amber Mendiola

Name of Facility: Harbor Point Intensive - North Unit

Facility Address: Upper Level
16908 130th St.
Nunica, MI 49448

Facility Telephone #: (616) 844-0663

Capacity: 6

Program Type: MENTALLY ILL
DEVELOPMENTALLY DISABLED

II. Purpose of Addendum

On 07/27/2017, I received a written request to approve the lower level of the facility for resident use.

III. Methodology

During a renewal inspection on 07/11/2017, while inspecting the lower level, I considered it's use for residents in anticipation of the request.

IV. Description of Findings and Conclusions

I find that the lower level more than meets minimum licensing standards in that there are 3 means of egress; the stairs to the main floor and 2 doors that open directly to the outside.

V. Recommendation

I recommend that the lower level of the facility be utilized for regular resident recreational use.



07/28/2017

Grant Sutton
Licensing Consultant

Date