



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

SHELLY EDGERTON  
DIRECTOR

October 29, 2018

Princess Kennedy  
Asanpee Care  
PO Box 85766  
Westland, MI 48185

RE: License #: AS820286497  
**Princess Home**  
**29605 Glenwood**  
**Inkster, MI 48141**

Dear Ms. Kennedy:

Attached is the Renewal Licensing Study Report for the facility referenced above. You have submitted an acceptable written corrective action plan addressing the violations cited in the report. To verify your implementation and compliance with this corrective action plan:

- An on-site inspection will be conducted.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (313) 456-0380.

Sincerely,

A handwritten signature in cursive script that reads "Regina Buchanan".

Regina Buchanan, Licensing Consultant  
Bureau of Community and Health Systems  
Cadillac Pl. Ste 9-100  
3026 W. Grand Blvd  
Detroit, MI 48202  
(313) 949-3029

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF COMMUNITY AND HEALTH SYSTEMS  
RENEWAL INSPECTION REPORT**

**I. IDENTIFYING INFORMATION**

**License #:** AS820286497

**Licensee Name:** Asanpee Care

**Licensee Address:** 415 Belton Street  
Garden City, MI 48135

**Licensee Telephone #:** (313) 522-9587

**Licensee/Licensee Designee:** Princess Kennedy

**Administrator:** Princess Kennedy

**Name of Facility:** Princess Home

**Facility Address:** 29605 Glenwood  
Inkster, MI 48141

**Facility Telephone #:** (313) 522-9587

**Original Issuance Date:** 12/27/2006

**Capacity:** 6

**Program Type:** PHYSICALLY HANDICAPPED  
DEVELOPMENTALLY DISABLED  
MENTALLY ILL  
TRAUMATICALLY BRAIN INJURED

**II. METHODS OF INSPECTION**

Date of On-site Inspection(s): 10/25/2018

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Health Authority Inspection if applicable: N/A

Inspection Type:  Interview and Observation  Worksheet  
 Combination  Full Fire Safety

No. of staff interviewed and/or observed 2  
No. of residents interviewed and/or observed 2  
No. of others interviewed 0 Role: N/A

- Medication pass / simulated pass observed? Yes  No  If no, explain.
- Medication(s) and medication record(s) reviewed? Yes  No  If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes  No  If no, explain.
- Meal preparation / service observed? Yes  No  If no, explain.  
Residents had already eaten
- Fire drills reviewed? Yes  No  If no, explain.
- Fire safety equipment and practices observed? Yes  No  If no, explain.
- E-scores reviewed? (Special Certification Only) Yes  No  N/A   
If no, explain.
- Water temperatures checked? Yes  No  If no, explain.
- Incident report follow-up? Yes  No  If no, explain.
- Corrective action plan compliance verified? Yes  CAP date/s and rule/s:  
N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes  (please explain) No  N/A

### III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

**R 400.14316**

**Resident records.**

**(2) Resident records shall be kept on file in the home for 2 years after the date of a resident's discharge from a home.**

Requested files for discharged residents were not available for review.

**R 400.14511**

**Flame-producing equipment; enclosures.**

**(2) Heating plants and other flame-producing equipment located on the same level as the residents shall be enclosed in a room that is constructed of material which has a 1-hour-fire resistance rating, and the door shall be made of 1 3/4-inch solid core wood. The door shall be hung in a fully stopped wood or steel frame and shall be equipped with an automatic self-closing device and positive-latching hardware.**

The heating plant door was no longer self-closing.

### IV. RECOMMENDATION

An acceptable corrective action plan has been received. Renewal of the license is recommended.



---

Regina Buchanan  
Licensing Consultant

10/29/2018  
Date