



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

December 16, 2021

Laketa Brodnex
D.E.B. AFC Inc.
P.O Box 136
Bridgeport, MI 48722

RE: License #: AS730287431
D.E.B. AFC, Inc. #2
3197 Studor
Saginaw, MI 48601

Dear Mrs. Brodnex:

Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the licensee or licensee designee or home for the aged authorized representative and a date.

Upon receipt of an acceptable corrective plan, a regular license will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (517) 284-9730.

Sincerely,

A handwritten signature in cursive script that reads "C. Garza".

Christina Garza, Licensing Consultant
Bureau of Community and Health Systems
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909
(810) 240-2478

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #: AS730287431

Licensee Name: D.E.B. AFC Inc.

Licensee Address: P.O Box 136
Bridgeport, MI 48722

Licensee Telephone #: (989) 714-0793

Licensee/Licensee Designee: Laketa Brodnex

Administrator: Laketa Brodnex

Name of Facility: D.E.B. AFC, Inc. #2

Facility Address: 3197 Studor
Saginaw, MI 48601

Facility Telephone #: (989) 777-6903

Original Issuance Date: 05/16/2007

Capacity: 6

Program Type: PHYSICALLY HANDICAPPED
DEVELOPMENTALLY DISABLED
MENTALLY ILL
ALZHEIMERS
AGED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 12/16/2021

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Health Authority Inspection if applicable: N/A

Inspection Type: Interview and Observation Worksheet
 Combination Full Fire Safety

No. of staff interviewed and/or observed 2

No. of residents interviewed and/or observed 4

No. of others interviewed 0 Role: N/A

- Medication pass / simulated pass observed? Yes No If no, explain.
- Medication(s) and medication record(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes No If no, explain.
- Meal preparation / service observed? Yes No If no, explain.
It was not meal time at time of inspection.
- Fire drills reviewed? Yes No If no, explain.
- Fire safety equipment and practices observed? Yes No If no, explain.
- E-scores reviewed? (Special Certification Only) Yes No N/A
If no, explain.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes No If no, explain.
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
12/16/19; 12/2/19; 4/24/19; 1/25/19 N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes (please explain) No N/A

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 400.14402 Food service.

(3) All perishable food shall be stored at temperatures that will protect against spoilage. All potentially hazardous food shall be kept at safe temperatures. This means that all cold foods are to be kept cold, 40 degrees Fahrenheit or below, and that all hot foods are to be kept hot, 140 degrees Fahrenheit or above, except during periods that are necessary for preparation and service. Refrigerators and freezers shall be equipped with approved thermometers.

At time of inspection, refrigerator was not equipped with thermometer.

R 400.14403 Maintenance of premises.

(1) A home shall be constructed, arranged, and maintained to provide adequately for the health, safety, and well-being of occupants.

At time of inspection, dryer vent needs to be constructed of solid material

R 400.14403 Maintenance of premises.

(4) A roof, exterior walls, doors, skylights, and windows shall be weathertight and watertight and shall be kept in sound condition and good repair.

At time of inspection, bathroom doors were damaged and in need of repair.

R 400.14403 Maintenance of premises.

(5) Floors, walls, and ceilings shall be finished so as to be easily cleanable and shall be kept clean and in good repair.

At time of inspection, kitchen flooring was damaged and in need of repair.

R 400.14506 Fire extinguishers; location, examination, and maintenance.

(1) A minimum of 1 underwriters laboratories approved 2A 10BC extinguisher or equivalent shall be provided for use in a small group home on each occupied floor and in the basement.

At time of inspection, there was no fire extinguishers in basement and each occupied floor.

IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license is recommended.



12/16/2021

Christina Garza
Licensing Consultant

Date