



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

ORLENE HAWKS  
DIRECTOR

November 24, 2021

Jzsa-Jaza Gibson  
Pharaoh's Rest Haven, LLC  
1102 S. West Avenue  
Jackson, MI 49203

RE: License #: AS380406021  
**Pharaoh's Rest Haven**  
**1044 S. MLK Jr. Drive**  
**Jackson, MI 49203**

Dear Ms. Gibson:

This letter is a follow-up to the Department's findings regarding the interim inspection conducted at your facility on 11/22/2021. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for an Adult Foster Care small group home.

The violations that were found are:

**R 400.14401 Environmental health.**

(2) Hot and cold running water that is under pressure shall be provided. A licensee shall maintain the hot water temperature for a resident's use at a range of 105 degrees Fahrenheit to 120 degrees Fahrenheit at the faucet.

- The hot water temperature was 152.8 degrees Fahrenheit at the faucet.


Due to the violations identified in the report, **a written corrective action plan** is required. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific time frames for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the responsible party and a date.

The Department provides technical assistance to meet the licensing requirements and consultation to improve services.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (313) 456-0380.

Sincerely,



Mahtina Rubritius, Licensing Consultant  
Bureau of Community and Health Systems  
Cadillac Place  
3026 W. Grand Blvd., Ste. #9-100  
Detroit, MI 48202  
(517) 262-8604

Enclosures