



STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

GRETCHEN WHITMER
GOVERNOR

ORLENE HAWKS
DIRECTOR

July 5, 2023

LouAnn Wilson
New Haven Foster Care Inc
230 Hoehn Court
Dimondale, MI 48821

RE: License #: AM230065427
New Haven Foster Care
230 Hoehn Court
Dimondale, MI 48821

Dear Ms. Wilson:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (517) 284-9730.

Sincerely,

A handwritten signature in cursive script that reads "Jana Lipps".

Jana Lipps, Licensing Consultant
Bureau of Community and Health Systems
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	AM230065427
Licensee Name:	New Haven Foster Care Inc
Licensee Address:	230 Hoehn Court Dimondale, MI 48821
Licensee Telephone #:	(517) 282-1886
Licensee Designee:	LouAnn Wilson
Administrator:	LouAnn Wilson
Name of Facility:	New Haven Foster Care
Facility Address:	230 Hoehn Court Dimondale, MI 48821
Facility Telephone #:	(517) 646-9451
Capacity:	12
Program Type:	PHYSICALLY HANDICAPPED AGED

II. Purpose of Addendum

An AFC Licensing Renewal Inspection was completed at the facility on 12/2/22 and it was found that the licensee designee, LouAnn Wilson, was caring for residents who require the use of a wheelchair. The Original Licensing Study Report did not provide approval for residents who require wheelchair access. Ms. Wilson has requested to modify the terms of her license to include wheelchair accessibility. She submitted a *Request for Modification of the Terms of the Registration/License* form dated 6/28/23.

III. Methodology

An on-site renewal inspection was completed on 12/2/22. It was identified that the facility has doorways that are wide enough to accommodate wheelchair use, wheelchair accessible showers and bathrooms, and one means of egress that met wheelchair accessibility rules. Ms. Wilson has since modified an additional exit to accommodate wheelchair access by adding a wheelchair ramp with railings on each open side. The wheelchair ramp at both exits leads to a gravel pathway that leads residents a safe distance away from the facility.

IV. Description of Findings and Conclusions

Ms. Wilson has made appropriate modifications to the facility to accommodate wheelchair access by adding a second means of egress that complies with wheelchair accessibility standards. The facility is now equipped with two means of egress to allow for safe exiting, for individuals in wheelchairs, during an emergency.


V. Recommendation

Modify the license to include wheelchair accessibility.

 07/03/23

Jana Lipps Date
Licensing Consultant

Approved:

 07/05/2023

Dawn Timm Date
Area Manager