



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

August 2, 2023

Lilly Hayes
Elmira Inc
25855 Carlisle
Inkster, MI 48141

RE: License #: AS820014194
Floral - Elmira AFC
18110 Floral
Livonia, MI 48152

Dear Ms. Hayes:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (313) 456-0380.

Sincerely,

A handwritten signature in blue ink that reads "K. Robinson".

K. Robinson, LMSW, Licensing Consultant
Bureau of Community and Health Systems
Cadillac Pl. Ste 9-100
3026 W. Grand Blvd
Detroit, MI 48202
(313) 919-0574

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	AS820014194
Licensee Name:	Elmira Inc
Licensee Address:	25855 Carlisle Inkster, MI 48141
Licensee Telephone #:	(734) 459-6424
Administrator/Licensee Designee:	Lilly Hayes, Designee
Name of Facility:	Floral - Elmira AFC
Facility Address:	18110 Floral Livonia, MI 48152
Facility Telephone #:	(734) 422-2238
Capacity:	6
Program Type:	PHYSICALLY HANDICAPPED DEVELOPMENTALLY DISABLED

II. Purpose of Addendum

To make the home wheelchair accessible.

III. Methodology

On 5/25/23, I completed an onsite inspection at the facility to measure the 2 new ramps installed at the front door and side door near the garage. The ramp at the side door was 3 feet short, initially measuring at only 21 feet of run. The side entrance door sits 2 feet above ground; therefore, requiring 24 feet of run.

On 7/19/23, I completed a follow up inspection at the facility. The ramp at the side door had been corrected to add an additional 3 feet of run meeting the 24-foot requirement.

Both ramps are 24 feet long, not including the landing where it changes direction.

IV. Description of Findings and Conclusions

Both ramps at the required means of egress have 24 feet of run which meets the licensing requirement to accommodate residents that require the regular use of a wheelchair.

V. Recommendation

I recommend the home be approved to accept and retain residents with wheelchairs.



8/2/23

Kara Robinson
Licensing Consultant

Date