



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

December 5, 2024

Marcia Wheeler
Real Place Inc.
25630 W. Chicago
Redford, MI 48239

RE: License #: AS820273887
Real Place Inc.
25630 W. Chicago
Redford, MI 48239

Dear Marcia Wheeler:

Attached is the Renewal Licensing Study Report for the facility referenced above. You have submitted an acceptable written corrective action plan addressing the violations cited in the report. To verify your implementation and compliance with this corrective action plan:

- You are to submit a Statement of Correction.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (313) 456-0380.

Sincerely,

A handwritten signature in cursive script that reads "Regina Buchanan".

Regina Buchanan, Licensing Consultant
Bureau of Community and Health Systems
Cadillac Pl. Ste 9-100
3026 W. Grand Blvd
Detroit, MI 48202
(313) 949-3029

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #:	AS820273887
Licensee Name:	Real Place Inc.
Licensee Address:	25630 W. Chicago Redford, MI 48239
Licensee Telephone #:	(313) 673-1808
Licensee/Licensee Designee:	Marcia Wheeler
Administrator:	Marcia Wheeler
Name of Facility:	Real Place Inc.
Facility Address:	25630 W. Chicago Redford, MI 48239
Facility Telephone #:	(313) 937-1664
Original Issuance Date:	06/29/2005
Capacity:	6
Program Type:	DEVELOPMENTALLY DISABLED MENTALLY ILL

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 12/04/2024

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Health Authority Inspection if applicable: N/A

No. of staff interviewed and/or observed 3

No. of residents interviewed and/or observed 5

No. of others interviewed 0 Role: N/A

- Medication pass / simulated pass observed? Yes No If no, explain.
- Medication(s) and medication record(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes No If no, explain.
- Meal preparation / service observed? Yes No If no, explain.
Residents had eaten
- Fire drills reviewed? Yes No If no, explain.
- Fire safety equipment and practices observed? Yes No If no, explain.
- E-scores reviewed? (Special Certification Only) Yes No N/A
If no, explain.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes No If no, explain.
None
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
12/14/2022 Rule 401 (2) N/A
- Number of excluded employees followed-up? 1 N/A
- Variances? Yes (please explain) No N/A

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 400.14507 Means of egress generally.

(5) A door that forms a part of a required means of egress shall be not less than 30 inches wide and shall be equipped with positive-latching, non-locking-against-egress hardware.

The front egress screen door was equipped with locking against egress hardware.

IV. RECOMMENDATION

An acceptable corrective action plan has been received. Renewal of the license is recommended.



Regina Buchanan
Licensing Consultant

12/05/2024
Date