



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

February 13, 2026

Karon Lee
Michigan Community Services, Inc.
PO Box 317
Swartz Creek, MI 48473

RE: License #:	AS090010209 Knight Road Home CLF 1544 Knight Road Essexville, MI 48732
----------------	---

Dear Karon Lee:

Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the licensee or licensee designee or home for the aged, authorized representative and a date.

Upon receipt of an acceptable corrective plan, a regular license and special certification will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (517) 643-7960.

Sincerely,

A handwritten signature in cursive script, appearing to read "Shamidah Wyden".

Shamidah Wyden, Licensing Consultant
Bureau of Community and Health Systems
411 Genesee
P.O. Box 5070
Saginaw, MI 48607
989-395-6853

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License#:	AS090010209
Licensee Name:	Michigan Community Services, Inc.
Licensee Address:	5239 Morrish Rd. Swartz Creek, MI 48473
Licensee Telephone #:	(810) 635-4407
Licensee Designee:	Karon Lee
Administrator:	Karon Lee
Name of Facility:	Knight Road Home CLF
Facility Address:	1544 Knight Road Essexville, MI 48732
Facility Telephone #:	(989) 892-8600
Original Issuance Date:	12/01/1995
Capacity:	6
Program Type:	PHYSICALLY HANDICAPPED DEVELOPMENTALLY DISABLED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 02/10/2026

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Environmental/Health Inspection if applicable: N/A

No. of staff interviewed and/or observed 2

No. of residents interviewed and/or observed 5

No. of others interviewed 1 Role: Area Supervisor

- Medication pass / simulated pass observed? Yes No If no, explain.
- Medication(s) and medication record(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes No If no, explain.
- Meal preparation / service observed? Yes No If no, explain.
Inspection not conducted during mealtime.
- Fire drills reviewed? Yes No If no, explain.
- Fire safety equipment and practices observed? Yes No If no, explain.
- E-scores reviewed? (Special Certification Only) Yes No N/A
If no, explain.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes No If no, explain.
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
02/07/2024 R403(1); 08/26/2024 R305(2) N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes (please explain) No N/A


III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:	
R 400.631	Health screenings.
	(4) A licensee shall annually review and maintain in the facility the health status of the staff and members of the household. Verification of annual reviews must be maintained for 2 years.
At the time of inspection, staff Jackie Rothwell and staff Dasha Walker's staff files did not have up to date annual health reviews.	
R 400.645	Environmental health.
	(3) A licensee shall provide hot and cold running water under pressure. A licensee shall maintain the hot water temperature for a resident's use at a range of 105 degrees Fahrenheit to 120 degrees Fahrenheit at the fixture.
At the time of inspection, the bathrooms and kitchen water temperatures read above 120 degrees Fahrenheit.	
R 400.647	Safety and maintenance of premises.
	(1) A facility must be constructed, arranged, and maintained to provide adequately for the health, safety, and well-being of occupants.
At the time of inspection, the wood framing of the fire door located at the bottom of the basement stairs was broken, and in need of repair.	
R 400.661	Bedroom furnishings.
	(4) Resident bedrooms must have lighting for reading and other activities, equipped with an accessible mirror appropriate for grooming, and provisions to allow a resident to mount pictures or decorative items on walls.
At the time of inspection, Resident A's bedroom was not equipped with a mirror.	
R 400.675	Resident medications.
	(4) A licensee, administrator, or direct care staff shall comply with the following when supervising the taking of medication by a resident: (b) Complete an individual medication log that contains all of the following:

	(v) Initials of the individual who administered the medication at the time given.
At the time of inspection, the medication administration records for Resident A were missing staff initials for multiple 8:00 am medication passes on 01/15/2026 and 01/23/2026.	
R 400.729	Heating equipment.
	(2) A furnace, water heater, heating appliances, pipes, wood-burning stoves and furnaces, and other flame- or heat-producing equipment must be installed in a fixed or permanent manner and in accordance with a manufacturer's instructions and maintained in a safe condition. Clothes dryers must be properly vented to the outside using permanent metal duct work.
At the time of inspection, the duct work for the clothes dryer was observed to not be fully metal.	

IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license and issuance of the special certification is recommended.



02/13/2026

Shamidah Wyden
Licensing Consultant

Date