



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

MARLON I. BROWN, DPA  
DIRECTOR

April 6, 2026

Jennifer Bhaskaran  
Alternative Services Inc.  
Suite 10  
32625 W Seven Mile Rd  
Livonia, MI 48152

RE: License #: AS330011149  
**Van Atta Rd Home**  
**4817 Van Atta Rd**  
**Okemos, MI 48864**

Dear Ms. Bhaskaran:

Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the licensee or licensee designee.

Upon receipt of an acceptable corrective plan, a regular license will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (517) 335-5985.

Sincerely,



Amanda Blasius, Licensing Consultant  
Bureau of Community and Health Systems  
611 W. Ottawa Street  
P.O. Box 30664  
Lansing, MI 48909

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF COMMUNITY AND HEALTH SYSTEMS  
RENEWAL INSPECTION REPORT**

**I. IDENTIFYING INFORMATION**

**License #:** AS330011149

**Licensee Name:** Alternative Services Inc.

**Licensee Address:** Suite 10  
32625 W Seven Mile Rd  
Livonia, MI 48152

**Licensee Telephone #:** (248) 471-4880

**Licensee/Licensee Designee:** Jennifer Bhaskaran, Designee

**Administrator:** Jeremy Hagerman

**Name of Facility:** Van Atta Rd Home

**Facility Address:** 4817 Van Atta Rd  
Okemos, MI 48864

**Facility Telephone #:** (517) 349-1244

**Original Issuance Date:** 03/10/1982

**Capacity:** 6

**Program Type:** DEVELOPMENTALLY DISABLED

**II. METHODS OF INSPECTION**

Date of On-site Inspection(s): 04/01/2026

Date of Bureau of Fire Services Inspection if applicable: NA

Date of Environmental/Health Inspection if applicable: 3/17/2026

No. of staff interviewed and/or observed 3

No. of residents interviewed and/or observed 4

No. of others interviewed [redacted] Role: [redacted]

- Medication pass / simulated pass observed? Yes  No  If no, explain.
- Medication(s) and medication record(s) reviewed? Yes  No  If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes  No  If no, explain.
- Meal preparation / service observed? Yes  No  If no, explain.
- Fire drills reviewed? Yes  No  If no, explain.
- Fire safety equipment and practices observed? Yes  No  If no, explain.
- E-scores reviewed? (Special Certification Only) Yes  No  N/A  If no, explain.
- Water temperatures checked? Yes  No  If no, explain.
- Incident report follow-up? Yes  No  If no, explain.
- Corrective action plan compliance verified? Yes  CAP date/s and rule/s: 1/16/26: 693(2) 671(4) 645(6) 669(1) N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes  (please explain) No  N/A

### III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

**R 400.655**

**Bathrooms.**

**(1) Bathroom and toilet amenities with windows must open easily for ventilation. Amenities without a window must have forced ventilation to the outside.**

At the time of inspection, bathroom number one did not have a forced vent that was properly working.

### IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license is recommended.



04/06/2026

---

Amanda Blasius  
Licensing Consultant

Date