



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

May 20, 2026

Roland Higgs
Family Living Center Inc.
Suite 220
2350 Franklin Rd.
Bloomfield Hills, MI 48302

RE: License #: AS630377628
Rainbow Group Home
19331 Rainbow Drive
Lathrup Village, MI 48076

Dear Mr. Higgs:


Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the licensee or licensee designee or home for the aged authorized representative and a date.

Upon receipt of an acceptable corrective plan, a regular license will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (248) 972-9136.

Sincerely,

A handwritten signature in cursive script that reads "Cindy Berry". The signature is fluid and elegant, with the first and last names clearly distinguishable.

Cindy Berry, Licensing Consultant
Bureau of Community and Health Systems
Cadillac Place
3044 West Grand Blvd
2nd Floor Annex, Suite 2-730
Detroit, MI 48202
(248) 860-4475

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #:	AS630377628
Licensee Name:	Family Living Center Inc.
Licensee Address:	Suite 220 2350 Franklin Rd. Bloomfield Hills, MI 48302
Licensee Telephone #:	(248) 334-5330
Licensee Designee/Administrator:	Roland Higgs
Name of Facility:	Rainbow Group Home
Facility Address:	19331 Rainbow Drive Lathrup Village, MI 48076
Facility Telephone #:	(248) 569-8289
Original Issuance Date:	12/03/2015
Capacity:	6
Program Type:	DEVELOPMENTALLY DISABLED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 05/19/2026

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Environmental/Health Inspection if applicable: N/A

No. of staff interviewed and/or observed 2

No. of residents interviewed and/or observed 2

No. of others interviewed 0 Role: N/A

- Medication pass / simulated pass observed? Yes ☒ No ☐ If no, explain.
- Medication(s) and medication record(s) reviewed? Yes ☒ No ☐ If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes ☒ No ☐ If no, explain.
- Meal preparation / service observed? Yes ☐ No ☒ If no, explain.
There was no meal preparation/service provided at the time the on-site was conducted.
- Fire drills reviewed? Yes ☒ No ☐ If no, explain.
- Fire safety equipment and practices observed? Yes ☒ No ☐ If no, explain.
- E-scores reviewed? (Special Certification Only) Yes ☒ No ☐ N/A ☐
If no, explain.
- Water temperatures checked? Yes ☒ No ☐ If no, explain.
- Incident report follow-up? Yes ☒ No ☐ If no, explain.
- Corrective action plan compliance verified? Yes ☒ CAP date/s and rule/s:
CAP dated 7/11/2024; R 400 204(3)(b)m 204(3)(c), 401(2), 403(1), 408(4),
301(4), 301(6), 312(2), S803(1) N/A ☐
- Number of excluded employees followed-up? N/A ☒
- Variances? Yes ☐ (please explain) No ☐ N/A ☒

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 400.645

Environmental health.

(8) A habitable room must have direct outside ventilation by means of windows, louvers, air-conditioning, or mechanical ventilation. From April to November, each door, openable window, or other opening to the outside that is used for ventilation purposes must be supplied with a standard screen of not less than 16 mesh.

The screen in the window in bedroom #1 was torn.

R 400.647

Safety and maintenance of premises.

(1) A facility must be constructed, arranged, and maintained to provide adequately for the health, safety, and well-being of occupants.

There were weeds growing through the cracks on the ramp at the front of the home.

R 400.647

Safety and maintenance of premises.

(16) Yard areas must be kept reasonably free from hazards, nuisances, refuse, and litter.

- There was a large piece of plastic hanging over the outside railing near the stairwell at the back of the home.
- There was debris covering the outside stairwell at the back of the home.

R 400.655

Bathrooms.

(3) Bathrooms must have doors with positive-latching, non-locking-against-egress hardware. Hooks, bolts, bars, and other similar devices are prohibited on bathroom doors.

The bathroom door near the resident bedrooms contained hardware that was not positive-latching, non-locking-against-egress.

R 400.675 Resident medications.

(1) Medication must be given, taken, or applied as prescribed, ordered, or directed by an appropriately licensed health care professional.

On 5/03/2026, Resident B's medication Alprazolam 1 mg was still in the blister pack although the blister pack had been punched out. There was no explanation documented on the medication administration record (MAR).

REPEAT VIOLATION ESTABLISHED; LSR CAP APPROVED 7/11/2024.

R 400.675 Resident medications.

(2) Prescribed medication must be kept in the original pharmacy container and labeled for a specific resident. Over-the-counter medication must be kept in the original manufacturer's container. Prescription and over-the-counter medication must be kept in a locked cabinet or drawer and refrigerated if required. Equipment necessary to administer medication must be easily accessible and used only for the resident for whom it is prescribed unless generally used for all residents.

- Resident C's medication Hydrocortisone cream 2.5% was observed in an unlocked cabinet.
- Resident D's medication Ammonium Lactate cream 12% was observed in an unlocked cabinet.

R 400.675 Resident medications.

(4) A licensee, administrator, or direct care staff shall comply with the following when supervising the taking of medication by a resident:

(b) Complete an individual medication log that contains all of the following:

- (i) Medication name.
- (ii) Dosage.
- (iii) Label instructions for use.
- (iv) Time to be administered.
- (v) Initials of the individual who administered the medication at the time given.

- On 5/13/2026 Resident B's medication Alprazolam 1 mg appeared to have been administered but there were no staff initials observed on the MAR.
- Resident B's medication Alprazolam 2 mg PRN was not listed on the MAR.

R 400.691

Resident records.

- (1) A licensee shall complete and maintain a separate record for each resident that includes all of the following:
- (g) Admission and monthly weight record.

Resident A's weight was not documented for the months of July and August 2025.

R 400.715

Facility environment; fire safety, adoption by reference.

- (1) A facility that has a capacity of 4 to 6 residents shall be equipped with an interconnected multi-station smoke detection system that is powered by the facility's electrical service. When activated, the system must initiate an alarm that is audible in all areas of the facility. The smoke detection system must be installed on all levels, including basements, common activity areas, and outside each sleeping area, excluding crawl spaces and unfinished attics, to provide full coverage of the facility. The system must include a battery backup to ensure that the system is operable if there is an electrical power failure and accommodate the sensory impairments of residents living in the facility, if needed. A fire safety system must be installed in accordance with the manufacturer's instructions by a licensed electrical contractor and inspected annually. A record of the inspections must be maintained at the facility for 2 years.

The home is equipped with an interconnected multi-station smoke detection system. Individual detectors were tested and worked. However, the interconnection did not work between all stations.

IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license is recommended.

A handwritten signature in cursive script that reads "Cindy Berry".

5/20/2026

Cindy Berry
Licensing Consultant

Date