



STATE OF MICHIGAN
DEPARTMENT OF HUMAN SERVICES
BUREAU OF CHILDREN AND ADULT LICENSING



JENNIFER M. GRANHOLM
GOVERNOR

ISMAEL AHMED
DIRECTOR

July 17, 2009

Carolyn Brownell
821 Barton Drive
Ann Arbor, MI 48105

RE: License #: AF810085724
Barton Manor
821 Barton Drive
Ann Arbor, MI 48105

Dear Ms. Brownell:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and feel free to contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please feel free to contact the local office at (269) 337-5066.

Sincerely,

Chuck Wisman, Licensing Consultant
Bureau of Children and Adult Licensing
301 E. Louis Glick Hwy
Jackson, MI 49201
(517) 780-7548

enclosure

**MICHIGAN DEPARTMENT OF HUMAN SERVICES
BUREAU OF CHILDREN AND ADULT LICENSING
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	AF810085724
Licensee Name:	Carolyn Brownell
Licensee Address:	821 Barton Drive Ann Arbor, MI 48105
Licensee Telephone #:	(734) 662-7798
Administrator/Licensee Designee:	N/A
Name of Facility:	Barton Manor
Facility Address:	821 Barton Drive Ann Arbor, MI 48105
Facility Telephone #:	(734) 662-7798
Capacity:	6
Program Type:	AGED PHYSICALLY HANDICAPPED ALZHEIMERS MENTALLY ILL

II. Purpose of Addendum

Modification of admission requirements to allow persons confined to wheelchairs to reside in this facility.

III. Methodology

- July 2, 2009 Unscheduled on-site inspection
 Measured ramp pursuant to licensing construction standards and requirements

- July 9, 2009 Request for modification of the terms of the license signed and submitted.

IV. Description of Findings and Conclusions

On July 2, 2009, the ramp installed at a side entrance/exit was measured relative to meeting licensing requirements. The ramp began approximately 29 inches from ground level and the entire ramp measured 28 feet. The discrepancy of 1 foot in length was meaningless given the minimal difference of one foot in a span of 28 feet.

The installed ramp met the requirements of the family home licensing rules.

V. Recommendation

The original licensing study report is modified to include the admission of residents confined to wheelchairs.



July 17, 2009

Chuck Wisman
Licensing Consultant

Date