



STATE OF MICHIGAN
DEPARTMENT OF HUMAN SERVICES
BUREAU OF CHILDREN AND ADULT LICENSING



JENNIFER M. GRANHOLM
GOVERNOR

ISMAEL AHMED
DIRECTOR

December 6, 2010

Laura Sarrach
Golden Acre Residential Care, LLC
8353 Stoneham Dr.
Ypsilanti, MI 48197

RE: License #: AS810305079
Golden Acre Residential Care
8253 Stoneham Dr.
Ypsilanti, MI 48197

Dear Ms. Sarrach:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and feel free to contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please feel free to contact the local office at (269) 337-5066.

Sincerely,

Chuck Wisman, Licensing Consultant
Bureau of Children and Adult Licensing
301 E. Louis Glick Hwy
Jackson, MI 49201
(517) 780-7548

enclosure

**MICHIGAN DEPARTMENT OF HUMAN SERVICES
BUREAU OF CHILDREN AND ADULT LICENSING
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #: AS810305079

Licensee Name: Golden Acre Residential Care, LLC

Licensee Address: 8353 Stoneham Dr.
Ypsilanti, MI 48197

Licensee Telephone #: (734) 620-3895

Administrator/Licensee Designee: Laura Sarrach, Designee & Administrator

Name of Facility: Golden Acre Residential Care

Facility Address: 8253 Stoneham Dr.
Ypsilanti, MI 48197

Facility Telephone #: (734) 547-5058

Capacity: 6

Program Type: MENTALLY ILL
DEVELOPMENTALLY DISABLED
AGED
ALZHEIMERS
PHYSICALLY HANDICAPPED
TRAUMATICALLY BRAIN INJURED

II. Purpose of Addendum

Licensee submitted a request for modification of the license to allow the admission of persons confined to a wheel chair.

III. Methodology

09/16/2010: Request for modification submitted in writing by the licensee

11/04/2010: On-site inspection conducted in response to request for modification and license renewal

11/08/2010: Request for variance to ramp rule requirement

12/01/2010: Variance request approved by C.O.

IV. Description of Findings and Conclusions

Both the front and rear exterior exits are ramped; however, an internal ramp located inside the facility did not meet the 12:1 ramp slope requirement. A variance request was submitted, and the slope of 8'4":10 1/2" was approved.

V. Recommendation

Given approval of the ramp variance request, this facility may accept persons confined to a wheelchair.




December 62, 2010

Chuck Wisman
Licensing Consultant

Date

Approved By:



December 6, 2010

Gregory V. Corrigan
Area Manager

Date