



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

SHELLY EDGERTON
DIRECTOR

March 24, 2017

Kenneth Jordan
Samaritan Homes, Inc.
22610 Rosewood
Oak Park, MI 48237

RE: License #: AS820077107
Mill Creek Home
27312 Mill Creek
Brownstown, MI 48183

Dear Mr. Jordan:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (313) 456-0380.

Sincerely,

A handwritten signature in cursive script that reads "Shatonla Daniel".

Shatonla Daniel, Licensing Consultant
Bureau of Community and Health Systems
Cadillac Pl. Ste 9-100
3026 W. Grand Blvd
Detroit, MI 48202
(313) 919-3003

Enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	AS820077107
Licensee Name:	Samaritan Homes, Inc.
Licensee Address:	22610 Rosewood Oak Park, MI 48237
Licensee Telephone #:	(248) 399-8115
Administrator/Licensee Designee:	Kenneth Jordan
Name of Facility:	Mill Creek Home
Facility Address:	27312 Mill Creek Brownstown, MI 48183
Facility Telephone #:	(734) 675-5120
Capacity:	5
Program Type:	DEVELOPMENTALLY DISABLED MENTALLY ILL PHYSICALLY HANDICAPPED

II. Purpose of Addendum

Licensee designee has requested to wheelchair ramps in the facility and add to program type physically handicapped for residents. In addition, the licensee designee has requested a decrease in capacity from five to four.

III. Methodology

02/01/2017 Modification Request (Contained builders information, contractual plans, and invoices)

03/01/2017 Onsite Inspection

03/21/2017 Modification Request – Decrease capacity

IV. Description of Findings and Conclusions

The facility has two approved means of egress located in the front and side which are now equipped with wheelchair ramps. These ramps have handrails on the open sides. The main resident bathroom has been modified to accommodate wheelchair residents. All of these additions to the facility have been constructed in accordance with the requirements specified in licensing rules and the BOCA National Building Code, 1990, eleventh edition.

Location	Dimensions
Front Ramp	1.66 ft. rise X 14.5 ft. slope
Back Ramp	2.25 ft. rise X 6.33 ft. slope X 12.17 ft. slope X 5.25 ft. slope

V. Recommendation

I recommend physically handicapped be added to the license and the capacity to be decreased from five to four residents.



03/24/2017

Shatonla Daniel
Licensing Consultant

Date