



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

SHELLY EDGERTON  
DIRECTOR

May 21, 2018

Barry Bruns  
HomeLife Inc  
PMB #360  
5420A Beckley Rd.  
Battle Creek, MI 49015

RE: License #: AM030353416  
**691 W. Bridge Street AFC**  
**691 W. Bridge Street**  
**Plainwell, MI 49080**

Dear Mr. Bruns:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (616) 356-0183.

Sincerely,

A handwritten signature in cursive script, appearing to read "Ian Tschirhart".

Ian Tschirhart, Licensing Consultant  
Bureau of Community and Health Systems  
Unit 13, 7th Floor  
350 Ottawa, N.W.  
Grand Rapids, MI 49503  
(616) 644-9526

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF COMMUNITY AND HEALTH SYSTEMS  
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

**I. IDENTIFYING INFORMATION**

<b>License #:</b>	AM030353416
<b>Licensee Name:</b>	HomeLife Inc
<b>Licensee Address:</b>	3 Heritage Oak Lane Battle Creek, MI 49015
<b>Licensee Telephone #:</b>	(269) 660-0854
<b>Licensee Designee:</b>	Barry Bruns
<b>Administrator:</b>	Barry Bruns
<b>Name of Facility:</b>	691 W. Bridge Street AFC
<b>Facility Address:</b>	691 W. Bridge Street Plainwell, MI 49080
<b>Facility Telephone #:</b>	(269) 225-1021
<b>Capacity:</b>	12
<b>Program Type:</b>	DEVELOPMENTALLY DISABLED MENTALLY ILL TRAUMATICALLY BRAIN INJURED

## II. Purpose of Addendum

To change the purpose of one of the rooms from being an office into a resident bedroom.

## III. Methodology

On 05/17/2018, I received an email with a written request from Barry Bruns, Licensee Designee, for this room change.

On 05/17/2018, I sent Mr. Bruns an email acknowledging his request.

On 05/17/2018, I spoke with Mr. Bruns by phone and told him I would make an onsite inspection of the room on the morning of 05/21/2018.

On 05/21/2018, I made an onsite inspection and measure the proposed new bedroom, and also inspected the room's widow and door lock.

## IV. Description of Findings and Conclusions

The dimensions of the proposed new bedroom are 9' X 14', for a total of 126 square feet, which allows for a capacity of one resident. I verified that the window is easily openable and is large enough for an average sized person to fit through. Further, I observed that the lock on the door is fitted with one-motion hardware.

## V. Recommendation

I approve of the proposed new bedroom -the old office- for the use of one resident.



May 21, 2018

---

Ian Tschirhart  
Licensing Consultant

Date