



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

SHELLY EDGERTON
DIRECTOR

June 1, 2018

Jayne Glaza
First & Main of Commerce Township
2500 Martin Parkway
Commerce Township, MI 48390

RE: License #: AH630370124
First & Main of Commerce Township
2500 Martin Parkway
Commerce Township, MI 48390

Dear Ms. Glaza:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (517) 284-9720.

Sincerely,

A handwritten signature in cursive script that reads "Loma M Campbell".

Loma M Campbell, Licensing Staff
Bureau of Community and Health Systems
4th Floor, Suite 4B
51111 Woodward Avenue
Pontiac, MI 48342
(248) 860-3110

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT**

I. IDENTIFYING INFORMATION

License #:	AH630370124
Licensee Name:	F&M Commerce Township OPCO, LLC
Licensee Address:	#2200 2221 Health Drive, SW Wyoming, MI 49519
Licensee Telephone #:	(616) 248-3566
Authorized Representative:	Jayne Glaza
Administrator:	Colleen Higgins
Name of Facility:	First & Main of Commerce Township
Facility Address:	2500 Martin Parkway Commerce Township, MI 48390
Facility Telephone #:	(248) 387-2961
Capacity:	158
Program Type:	AGED ALZHEIMERS

II. Purpose of Addendum

On 2/05/2018, Kasra Zarbinian, Surveyor, DLARA/Health Facilities Engineering Section determined that the license bed capacity for the home should be decreased from 158 to 157 bed capacity.

III. Methodology

On 2/05/2018, Kasra Zarbinian provided room sheets that included the measurements and physical description of the room and various spaces in the home.

IV. Description of Findings and Conclusions

Room 234 was designed to be licensed for two beds, however, the living room window opens into the 3-season room which cannot be licensed as a bed room. In addition, Room 236 has the same similar situation with the windows to the bed room and living room opening to a 3-season room. Based on the description provided by Mr. Zarbinian, the licensed bed capacity for the home will be 157 beds because Room 234 and Room 236 cannot be licensed for two beds.

V. Recommendation


I recommend the licensed bed capacity be decreased from 158 to 157 beds.



6/01/2018

Loma M Campbell
Licensing Staff

Date



6/1/18

Russell Misiak
Area Manager