



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

February 9, 2022

Kimberly Rawlings
Beacon Specialized Living Services, Inc.
890 N. 10th St., Suite 110
Kalamazoo, MI 49009

RE: License #: AS380399315
Beacon Home at County Farm
4380 County Farm Road
Jackson, MI 49201

Dear Ms. Rawlings:

Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation?
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the licensee or licensee designee or home for the aged authorized representative and a date.

Upon receipt of an acceptable corrective plan, a regular license will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (313) 456-0380.

Sincerely,



Vanita C. Bouldin, Licensing Consultant
Bureau of Community and Health Systems
22 Center Street
Ypsilanti, MI 48198
(734) 395-4037

611 W. OTTAWA • P.O. BOX 30664 • LANSING, MICHIGAN 48909
www.michigan.gov/lara • 517-335-1980

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #: AS380399315

Licensee Name: Beacon Specialized Living Services, Inc.

Licensee Address: Suite 110
890 N. 10th St.
Kalamazoo, MI 49009

Licensee Telephone #: (269) 427-8400

Licensee/Licensee Designee: Kimberly Rawlings

Administrator: Shelly Keinath

Name of Facility: Beacon Home at County Farm

Facility Address: 4380 County Farm Road
Jackson, MI 49201

Facility Telephone #: (269) 427-8400

Original Issuance Date: 08/20/2019

Capacity: 6

Program Type: DEVELOPMENTALLY DISABLED
MENTALLY ILL

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 02/09/2022

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Health Authority Inspection if applicable: N/A

Inspection Type: Interview and Observation Worksheet
 Combination Full Fire Safety

No. of staff interviewed and/or observed 2

No. of residents interviewed and/or observed 4

No. of others interviewed [redacted] Role: [redacted]

- Medication pass / simulated pass observed? Yes No If no, explain.
Due to COVID-19.
- Medication(s) and medication record(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident?
Yes No If no, explain.
- Meal preparation / service observed? Yes No If no, explain.
No meals prepared/served during renewal inspection.
- Fire drills reviewed? Yes No If no, explain.
- Fire safety equipment and practices observed? Yes No If no, explain.
- E-scores reviewed? (Special Certification Only) Yes No N/A
If no, explain.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes No If no, explain.
No follow-up needed.
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes (please explain) No N/A

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 400.14511 Flame-producing equipment; enclosures.

(1) If the heating plant is located in the basement of a small group home, standard building material may be used for the floor separation. Floor separation shall also include at least 1 3/4-inch solid core wood door or equivalent to create a floor separation between the basement and the first floor.

Basement door at the top of the stairs that includes floor separation does not close independently – it does not latch.

IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license is recommended.



Vanita C. Bouldin
Licensing Consultant

Date: 02/09/2022