



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

December 15, 2022
Jason Schmidt
New Life Services Inc
36022 Five Mile Road
Livonia, MI 48154

RE: License #: AS630012572
Westbury
7246 Westbury Blvd
West Bloomfield, MI 48322

Dear Mr. Schmidt:

Attached is the Renewal Licensing Study Report for the facility referenced above. You have submitted an acceptable written corrective action plan addressing the violations cited in the report. To verify your implementation and compliance with this corrective action plan:

- You are to submit documentation of compliance.

The study has determined substantial compliance with applicable licensing statutes and administrative rules. Therefore, your license is renewed. It is valid only at your present address and is nontransferable.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (248) 975-5053.

Sincerely,

A handwritten signature in cursive script that reads 'Sheena Bowman'.

Sheena Bowman, Licensing Consultant
Bureau of Community and Health Systems
4th Floor, Suite 4B
51111 Woodward Avenue
Pontiac, MI 48342

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #:	AS630012572
Licensee Name:	New Life Services Inc
Licensee Address:	36022 Five Mile Road Livonia, MI 48154
Licensee Telephone #:	(734) 744-7334
Licensee/Licensee Designee:	Jason Schmidt
Administrator:	Jason Schmidt
Name of Facility:	Westbury
Facility Address:	7246 Westbury Blvd West Bloomfield, MI 48322
Facility Telephone #:	(734) 744-7334
Original Issuance Date:	04/26/1988
Capacity:	6
Program Type:	DEVELOPMENTALLY DISABLED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 12/15/2022

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Environmental/Health Inspection if applicable: N/A

No. of staff interviewed and/or observed 2

No. of residents interviewed and/or observed 2

No. of others interviewed [redacted] Role: [redacted]

- Medication pass / simulated pass observed? Yes No If no, explain.
- Medication(s) and medication record(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes No If no, explain.
- Meal preparation / service observed? Yes No If no, explain.
I did not observe meal preparation during the onsite.
- Fire drills reviewed? Yes No If no, explain.
- Fire safety equipment and practices observed? Yes No If no, explain.
- E-scores reviewed? (Special Certification Only) Yes No N/A
If no, explain.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes No If no, explain.
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
SI CAP Approved 09/11/19; 303(2), 206(1)
- LSR CAP Approved 01/13/21; 312(4), 315(3), 301(4), 301(10), 318(5) N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes (please explain) No N/A

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 330.1803 Facility environment; fire safety.

(5) The capability of the clients to evacuate a facility in the event of a fire shall be assessed using methods described in appendix f of the 1985 life safety code of the national fire protection association. Appendix f of the 1985 life safety code of the national fire protection association is adopted by reference as part of these rules. A copy of the adopted appendix f is available from the Department of Mental Health, Lewis Cass Building, Lansing, MI 48913, at cost. A copy of appendix f may also be obtained from the National Fire Protection Association Library, Battermarch Park, P.O. Box 9101, Quincy, Massachusetts 02269-9101, 1-800-344-3555. A prepaid fee may be required by the national fire protection association for a copy of appendix f. A price quote for copying of these pages may be obtained from the national fire protection association.

The E-scores for 2021 and 2022 were not completed on the required appendix f of the 1985 life safety code of the national fire protection association.

R 400.14301 Resident admission criteria; resident assessment plan; emergency admission; resident care agreement; physician's instructions; health care appraisal.

(4) At the time of admission, and at least annually, a written assessment plan shall be completed with the resident or the resident's designated representative, the responsible agency, if applicable, and the licensee. A licensee shall maintain a copy of the resident's written assessment plan on file in the home.

Resident A's assessment plan for 2021 and 2022 was not signed by the licensee designee, Jason Schmidt. Resident B's 2022 assessment plan was not signed by the licensee designee, Jason Schmidt.

R 400.14301 Resident admission criteria; resident assessment plan; emergency admission; resident care agreement; physician's instructions; health care appraisal.

(9) A licensee shall review the written resident care agreement with the resident or the resident's designated representative and responsible agency, if applicable, at least annually or more often if necessary.

Resident A's resident care agreement for 2022 was not available to review during the onsite.

R 400.14507 Means of egress generally.


(5) A door that forms a part of a required means of egress shall be not less than 30 inches wide and shall be equipped with positive-latching, non-locking-against-egress hardware.

Both means of egress do not have non-locking against egress hardware.

A corrective action plan was requested and approved on 12/15/2022. It is expected that the corrective action plan be implemented within the specified time frames as outlined in the approved plan. A follow-up evaluation may be made to verify compliance. Should the corrections not be implemented in the specified time, it may be necessary to reevaluate the status of your license.

IV. RECOMMENDATION

An acceptable corrective action plan has been received. Renewal of the license is recommended.



Sheena Bowman
Licensing Consultant

12/15/22
Date

