



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

MARLON I. BROWN, DPA  
DIRECTOR

October 24, 2024

Christopher Risner  
Dansville Country Care LLC  
P.O. Box 122  
Dansville, MI 48819

RE: License #: AS330316950  
**Dansville Country Care**  
**1060 S. Jackson Street**  
**Dansville, MI 48819**

Dear Christopher Risner:


Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature of the licensee designee and a date.

Upon receipt of an acceptable corrective plan, a regular license will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (517) 284-9730.

Sincerely,

A handwritten signature in black ink that reads "Mahtina Rubritius". The script is cursive and fluid.

Mahtina Rubritius, Licensing Consultant  
Bureau of Community and Health Systems  
611 W. Ottawa  
P.O. Box 30664  
Lansing, MI 48909  
(517) 262-8604

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF COMMUNITY AND HEALTH SYSTEMS  
RENEWAL INSPECTION REPORT**

**I. IDENTIFYING INFORMATION**

<b>License #:</b>	AS330316950
<b>Licensee Name:</b>	Dansville Country Care LLC
<b>Licensee Address:</b>	1060 S. Jackson St. Dansville, MI 48819
<b>Licensee Telephone #:</b>	(517) 623-0119
<b>Licensee/Licensee Designee:</b>	Christopher Risner
<b>Administrator:</b>	Christine Simon
<b>Name of Facility:</b>	Dansville Country Care
<b>Facility Address:</b>	1060 S. Jackson Street Dansville, MI 48819
<b>Facility Telephone #:</b>	(517) 623-0119
<b>Original Issuance Date:</b>	05/15/2012
<b>Capacity:</b>	6
<b>Program Type:</b>	AGED ALZHEIMERS

## II. METHODS OF INSPECTION

Date of On-site Inspection(s): 10/23/2024

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Health Authority Inspection if applicable: 07/18/2024

No. of staff interviewed and/or observed 2

No. of residents interviewed and/or observed 5

No. of others interviewed 0 Role:

- Medication pass / simulated pass observed? Yes ☒ No ☐ If no, explain.
- Medication(s) and medication record(s) reviewed? Yes ☒ No ☐ If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes ☒ No ☐ If no, explain.
- Meal preparation / service observed? Yes ☐ No ☒ If no, explain.  
The on-site inspection was not concurrent with the mealtimes.
- Fire drills reviewed? Yes ☒ No ☐ If no, explain.
- Fire safety equipment and practices observed? Yes ☒ No ☐ If no, explain.
- E-scores reviewed? (Special Certification Only) Yes ☐ No ☐ N/A ☒  
If no, explain.
- Water temperatures checked? Yes ☒ No ☐ If no, explain.
- Incident report follow-up? Yes ☐ No ☒ If no, explain.  
Incident reports are no longer required to be submitted to LARA.
- Corrective action plan compliance verified? Yes ☐ CAP date/s and rule/s:  
N/A ☒
- Number of excluded employees followed-up? N/A ☒
- Variances? Yes ☐ (please explain) No ☐ N/A ☒

### III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

**R 400.14511**


**Flame-producing equipment; enclosures.**

**(1) If the heating plant is located in the basement of a small group home, standard building material may be used for the floor separation. Floor separation shall also include at least 1 3/4-inch solid core wood door or equivalent to create a floor separation between the basement and the first floor.**

There was a gap between the base of the fire door and the floor, which impeded the floor separation.

### IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license is recommended.



10/24/2024

---

Mahtina Rubritius  
Licensing Consultant

Date