



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

March 6, 2025

Mariah Hicks
UNITY HOMECARE LLC
4562 Dobie Rd
Okemos, MI 48864

RE: License #: AS330417742
Dobie Rd - Unity Home Healthcare
4562 Dobie Rd
Okemos, MI 48864

Dear Ms. Hicks:

This letter is a follow-up to the Department's findings regarding the interim inspection conducted at your facility on 03/06/2025. The purpose of this inspection was to determine compliance with applicable licensing statutes and administrative rules for an Adult Foster Care small group home.

The violations that were found are:

R 400.14511 Flame-producing equipment; enclosures.

(1) If the heating plant is located in the basement of a small group home, standard building material may be used for the floor separation. Floor separation shall also include at least 1 3/4-inch solid core wood door or equivalent to create a floor separation between the basement and the first floor.


During the interim inspection it was identified that there was not adequate floor separation between the basement and the first floor of the facility. This was overlooked during the original inspection and will need to be remedied. A 1 3/4 inch solid core wood door or equivalent must be added at the top or the bottom of the basement staircase, leading from the dining room to the basement.

Please contact me when corrections have been completed and an on-site visit will be scheduled to determined compliance.

The Department provides technical assistance to meet the licensing requirements and consultation to improve services.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (517) 284-9730.

Sincerely,

A handwritten signature in cursive script that reads "Jana Lipps".

Jana Lipps, Licensing Consultant
Bureau of Community and Health Systems
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909

Enclosures