



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

February 23, 2026

Melanie & Todd Bartel
9339 Melrose St
Livonia, MI 48150

RE: License #: AF820409413
Bartel's AFC
9339 Melrose St
Livonia, MI 48150

Dear Melanie & Todd Bartel:

Attached is the Renewal Licensing Study Report for the facility referenced above. You have submitted an acceptable written corrective action plan addressing the violations cited in the report. To verify your implementation and compliance with this corrective action plan:

- An on-site inspection may be conducted.

The study has determined substantial compliance with applicable licensing statutes and administrative rules. Therefore, your license is renewed. It is valid only at your present address and is nontransferable.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (313) 456-0439.

Sincerely,

A handwritten signature in blue ink that reads "Jeffrey J. Bozsik".

Jeffrey J. Bozsik, Licensing Consultant
Bureau of Community and Health Systems
(734) 417-4277

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #: AF820409413

Licensee Name: Melanie & Todd Bartel

Licensee Address: 9339 Melrose St
Livonia, MI 48150

Licensee Telephone #:

Licensee/Licensee Designee: N/A

Administrator:

Name of Facility: Bartel's AFC

Facility Address: 9339 Melrose St
Livonia, MI 48150

Facility Telephone #: (734) 522-5608

Original Issuance Date: 08/31/2021

Capacity: 6

Program Type: DEVELOPMENTALLY DISABLED
MENTALLY ILL
AGED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 02/02/2026

Date of Bureau of Fire Services Inspection if applicable: NA

Date of Health Authority Inspection if applicable: NA

No. of staff interviewed and/or observed 2
No. of residents interviewed and/or observed 6
No. of others interviewed [redacted] Role: [redacted]

- Medication pass / simulated pass observed? Yes No If no, explain.
- Medication(s) and medication record(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes No If no, explain.
- Meal preparation / service observed? Yes No If no, explain.
- Fire drills reviewed? Yes No If no, explain.
- Fire safety equipment and practices observed? Yes No If no, explain.
- E-scores reviewed? (Special Certification Only) Yes No N/A
If no, explain.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes No If no, explain.
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
N/A
- Number of excluded employees followed-up? N/A
- Variances? Yes (please explain) No N/A

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 400.725 Means of egress.

(3) Doors that form a part of a required means of egress must be equipped with positive-latching, non-locking-against-egress hardware and have a width to allow for residents requiring wheelchairs or other devices to easily navigate through doorways.

The front door had a deadbolt lock.

R 400.731 Flame-producing equipment; enclosures.

(2) Heating plants and other flame-producing equipment located on the same level as the residents must be enclosed in a room that is constructed of material that has a 1-hour-fire-resistance rating and has a door made of 1-3/4-inch solid core wood. The door must be hung in a fully stopped wood or steel frame and must be equipped with an automatic self-closing device and positive-latching hardware.

The in-the-wall gas heating unit was not in an enclosed room with a 1-hour fire rated door.

A corrective action plan was requested and approved on 02/23/2026. It is expected that the corrective action plan be implemented within the specified time frames as outlined in the approved plan. A follow-up evaluation may be made to verify compliance. Should the corrections not be implemented in the specified time, it may be necessary to reevaluate the status of your license.

IV. RECOMMENDATION

An acceptable corrective action plan has been received. Renewal of the license is recommended.



Jeffrey J. Bozsik
Licensing Consultant

Date: 2/23/2026