



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

May 29, 2026

Jennifer Herald
Gaslight Village Assisted
2625 N. Adrian Highway
Adrian, MI 49221

RE: License #: AH460361737
Gaslight Village Assisted
2625 N. Adrian Highway
Adrian, MI 49221

Dear Licensee:

Attached is the Renewal Licensing Study Report for the facility referenced above. The violations cited in the report require the submission of a written corrective action plan. The corrective action plan is due 15 days from the date of this letter and must include the following:

- How compliance with each rule will be achieved.
- Who is directly responsible for implementing the corrective action for each violation.
- Specific dates for each violation as to when the correction will be completed or implemented.
- How continuing compliance will be maintained once compliance is achieved.
- The signature home for the aged authorized representative and a date.

Upon receipt of an acceptable corrective action plan, a regular license will be issued. If you fail to submit an acceptable corrective action plan, disciplinary action will result. Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please feel free to contact the local office at 877-458-2757.

Sincerely,

Jessica Rogers, Licensing Staff
Bureau of Community and Health Systems
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909
(517) 285-7433

enclosure

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT**

I. IDENTIFYING INFORMATION

License #:	AH460361737
Licensee Name:	Adrian Highway Opco LLC
Licensee Address:	4500 Dorr Street Toledo, OH 43615
Licensee Telephone #:	(419) 247-2800
Authorized Representative:	Jennifer Herald
Administrator:	Sarah Bendele
Name of Facility:	Gaslight Village Assisted
Facility Address:	2625 N. Adrian Highway Adrian, MI 49221
Facility Telephone #:	(517) 264-2284
Original Issuance Date:	09/08/2015
Capacity:	51
Program Type:	ALZHEIMERS AGED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 05/28/2026

Date of Bureau of Fire Services Inspection if applicable: 09/04/2025

Inspection Type: Interview and Observation Worksheet
 Combination

Date of Exit Conference: 05/28/2026

No. of staff interviewed and/or observed 10

No. of residents interviewed and/or observed 20

No. of others interviewed 0 Role N/A

- Medication pass / simulated pass observed? Yes No If no, explain.
- Medication(s) and medication records(s) reviewed? Yes No If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes No If no, explain. No resident funds held.
- Meal preparation / service observed? Yes No If no, explain.
- Fire drills reviewed? Yes No If no, explain.
Bureau of Fire Services reviews fire drills. Disaster plan reviewed.
- Water temperatures checked? Yes No If no, explain.
- Incident report follow-up? Yes IR date/s: N/A
- Corrective action plan compliance verified? Yes CAP date/s and rule/s:
- CAP dated 11/30/2023 to Licensing Study Report (LSR) dated 11/8/2023: R 325.1913(2), R 325.1922(5), R 325.1931(3), R 325.1932(2), R 325.1943(1), R 325.1964(9)(b), R 325.1970(7), R 325.1976(13)
- CAP dated 3/15/2024 to Special Investigation Report (SIR) 2024A1022015 dated 3/14/2024: R 325.1921(1)(b), R 325.1922(5)
- CAP dated 2/10/2026 to SIR 2026A0585023 dated 2/9/2026: R 325.1932(2)
- Number of excluded employees followed up? Zero, as verified in the workforce background check account on date of survey. N/A

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 325.1922 Admission and retention of residents.

(5) A home shall update each resident's service plan not less than annually or if there is a significant change in the resident's care needs. Changes must be communicated to the resident and the resident's authorized representative, if any.

Interview with administrator Sarah Bendele revealed service plans were reviewed with the resident and/or authorized representative, then signed as communicated; however, Residents A and B's service plans were not signed.

REPEAT VIOLATION ESTABLISHED.

[For reference, see LSR dated 11/8/2023, CAP dated 11/30/2023, and SIR 2024A1022015, CAP dated 3/15/2024]

R 325.1931 Employees; general provisions.

(3) The home shall designate 1 person on each shift to be supervisor of resident care during that shift. The supervisor of resident care shall be fully dressed, awake, and on the premises when on duty.

Review of the staff schedule from May 17, 2026, to May 23, 2026, revealed a shift supervisor was not identified on various days and shifts. For example, on the 10:00 PM to 6:00 AM shift, a shift supervisor was not identified on May 20, 2026, through May 23, 2026.

REPEAT VIOLATION ESTABLISHED.

[For reference, see LSR dated 11/8/2023, CAP dated 11/30/2023]

R 325.1970 Water supply systems.

(7) The temperature of hot water at plumbing fixtures used by residents shall be regulated to provide tempered water at a range of 105 to 120 degrees Fahrenheit.

Inspection of some resident rooms revealed they were not in compliance with this rule. For example, the water temperature in room 12 revealed it was 129.6 degrees Fahrenheit and room 8 was 103.8 degrees Fahrenheit.

REPEAT VIOLATION ESTABLISHED.

[For reference, see LSR dated 11/8/2023, CAP dated 11/30/2023]

IV. RECOMMENDATION

Contingent upon receipt of an acceptable corrective action plan, renewal of the license is recommended.



05/29/2026

Date

Licensing Consultant