GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

October 5, 2026

Laura Hatfield-Smith
REM Michigan LLC
Suite 1
6185 Tittabawassee
Saginaw, MI 48603

RE: License #: AS440419630
REM Michigan Farnsworth
1670 Woodbine Drive
Lapeer, MI 48446

Dear Laura Hatfield-Smith:

Attached is the Addendum to the Original Licensing Study Report for the above referenced facility.

Please review the enclosed documentation for accuracy and contact me with any questions. In the event that I am not available and you need to speak to someone immediately, please contact the local office at (517) 643-7960.

Sincerely,

Susan Hutchinson

Susan Hutchinson, Licensing Consultant
Bureau of Community and Health Systems
611 W. Ottawa Street
P.O. Box 30664
Lansing, MI 48909
(989) 293-5222

enclosure

MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
ADDENDUM TO ORIGINAL LICENSING STUDY REPORT

I. IDENTIFYING INFORMATION

License #:	AS440419630
Licensee Name:	REM Michigan LLC
Licensee Address:	South Suite 350 6600 France Ave Edina, MN 55435
Licensee Telephone #:	(989) 791-7174
Administrator/Licensee Designee:	Laura Hatfield-Smith Laura Hatfield-Smith
Name of Facility:	REM Michigan Farnsworth
Facility Address:	1670 Woodbine Drive Lapeer, MI 48446
Facility Telephone #:	(810) 667-6152
Capacity:	5
Program Type:	PHYSICALLY HANDICAPPED DEVELOPMENTALLY DISABLED MENTALLY ILL

II. Purpose of Addendum

The purpose of this addendum is to determine if this facility meets the criteria to be considered wheelchair accessible.

III. Methodology


09/29/2026	Contact – Face-to-Face I met with the LD, Laura Hatfield-Smith at the facility during a renewal inspection
09/29/2026	Inspection Completed On-Site
09/29/2026	Inspection Completed – BCAL Full-Compliance
09/30/2026	Contact – Document Received Modification request form received
10/05/2026	Modify Terms
10/05/2026	LSR Sent – Addendum

IV. Description of Findings and Conclusions

On 09/29/26, I conducted an onsite inspection of REM Michigan Farnsworth. I conducted a visual inspection of the facility. I measured the doorways for three of the bedrooms at the front of the facility, the egress doors to two of the exits, and the doorway to the barrier free bathroom. The doorways for the three bedrooms, the barrier free bathroom, the egress door leading from the kitchen to the front of the facility, and the egress door leading from the living room to the garage all measure 36-inches. This facility meets the requirements for barrier-free access to the front bedrooms, front bathroom, and two independent means of egress. In addition, I inspected and approved the two wheelchair ramps attached to this facility. One of the wheelchair ramps exits from the kitchen to the front of the facility, and the other wheelchair ramp exits from the living room to the garage of the facility. Both ramps meet the requirements according to barrier-free access.

V. Recommendation

I recommend that this facility is considered wheelchair accessible. The terms of this license have been changed to reflect the wheelchair accessible status.



October 5, 2026

Susan Hutchinson
Licensing Consultant

Date