GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

October 14, 2026

Olatunbosun Ajenifujah
Uttermost Care Inc
25256 Keeler
Redford, MI 48239

RE: License #: AS820420183
Keeler St. Home
25256 Keeler
Redford, MI 48239

Dear Olatunbosun Ajenifujah:

Attached is the Renewal Licensing Study Report for the facility referenced above. You have submitted an acceptable written corrective action plan addressing the violations cited in the report. To verify your implementation and compliance with this corrective action plan:

- You are to submit a Statement of Correction.

Please contact me with any questions. In the event that I am not available and you need to speak to someone immediately, you may contact the local office at (313) 456-0380.

Sincerely,

Regina Buchanan

Regina Buchanan, Licensing Consultant
Bureau of Community and Health Systems
Cadillac Place Ste 2-730
3044 W Grand Blvd, Annex
Detroit, MI 48202
(313) 949-3029

MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF COMMUNITY AND HEALTH SYSTEMS
RENEWAL INSPECTION REPORT

I. IDENTIFYING INFORMATION

License #:	AS820420183
Licensee Name:	Uttermost Care Inc
Licensee Address:	25256 Keeler Redford, MI 48239
Licensee Telephone #:	(313) 736-6824
Licensee/Licensee Designee:	Olatunbosun Ajenifujah
Administrator:	Olatunbosun Ajenifujah
Name of Facility:	Keeler St. Home
Facility Address:	25256 Keeler Redford, MI 48239
Facility Telephone #:	(313) 740-7083
Original Issuance Date:	04/16/2026
Capacity:	6
Program Type:	DEVELOPMENTALLY DISABLED MENTALLY ILL AGED

II. METHODS OF INSPECTION

Date of On-site Inspection(s): 10/13/2026

Date of Bureau of Fire Services Inspection if applicable: N/A

Date of Health Authority Inspection if applicable: N/A

No. of staff interviewed and/or observed 2
No. of residents interviewed and/or observed 2
No. of others interviewed 0 Role: N/A

- Medication pass / simulated pass observed? Yes ☒ No ☐ If no, explain.
- Medication(s) and medication record(s) reviewed? Yes ☒ No ☐ If no, explain.
- Resident funds and associated documents reviewed for at least one resident? Yes ☒ No ☐ If no, explain.
- Meal preparation / service observed? Yes ☐ No ☒ If no, explain.
  The residents had already eaten.
- Fire drills reviewed? Yes ☒ No ☐ If no, explain.
- Fire safety equipment and practices observed? Yes ☒ No ☐ If no, explain.
- E-scores reviewed? (Special Certification Only) Yes ☒ No ☐ N/A ☐
  If no, explain.
- Water temperatures checked? Yes ☒ No ☐ If no, explain.
- Incident report follow-up? Yes ☐ No ☒ If no, explain.
  None
- Corrective action plan compliance verified? Yes ☒ CAP date/s and rule/s:
  N/A ☒
- Number of excluded employees followed-up? N/A ☒
- Variances? Yes ☐ (please explain) No ☐ N/A ☒

III. DESCRIPTION OF FINDINGS & CONCLUSIONS

This facility was found to be in non-compliance with the following rules:

R 400.645 Environmental health.

(3) A licensee shall provide hot and cold running water under pressure. A licensee shall maintain the hot water temperature for a resident's use at a range of 105 degrees Fahrenheit to 120 degrees Fahrenheit at the fixture.

The hot water temperature was 136 degrees Fahrenheit.

R 400.675 Resident medications.

(4) A licensee, administrator, or direct care staff shall comply with the following when supervising the taking of medication by a resident:
(b) Complete an individual medication log that contains all of the following:
(i) Medication name.
(ii) Dosage.
(iii) Label instructions for use.
(iv) Time to be administered.
(v) Initials of the individual who administered the medication at the time given.
(vi) Resident's refusal to accept prescribed medication or procedures at time of refusal.

Resident A's medications were not initialed on the medication log to verify administration on 08/31/2026.

R 400.715 Facility environment; fire safety, adoption by reference.

(4) Evacuation assessments must be conducted within 30 days after the admission of each new resident and at least annually after the admission of the last new resident. A licensee shall forward a copy of each completed assessment to the responsible agency and retain a copy in the facility for 2 years. A facility that is assessed as having an evacuation difficulty index of "impractical" using appendix f of the 2021 edition of NFPA 101, Life Safety Code, which is adopted by reference in subdivision (b) of this subrule, shall have a period of 6 months after the date of the finding to do either of the following:

(a) Improve the score to at least the "slow" category.
(b) Bring the facility into compliance with the physical plant standards for "impractical" facilities contained in chapter 33 of the 2021 edition of NFPA 101, Life Safety Code. NFPA 101, Life Safety Code, 2021 edition is adopted by reference and available to purchase on the National Fire Protection Association website at https:// www.nfpa.org at a cost of $168.00 for nonmembers of the NFPA and $151.20 for NFPA members at the time of adoption of these rules. A copy of NFPA 101 is available for inspection and distribution from the Bureau of Community and Health Services, Department of Licensing and Regulatory Affairs, 611 West Ottawa Street, P.O. Box 30664, Lansing, Michigan 48909 at a cost of 15 cents per page as of the time of the adoption by reference of NFPA 101.

The residents' evacuation assessments were not completed within 30 days of admission, and the total resident score and staff score pages were not accurately completed.

R 400.731 Flame-producing equipment; enclosures.

(2) Heating plants and other flame-producing equipment located on the same level as the residents must be enclosed in a room that is constructed of material that has a 1-hour-fire-resistance rating and has a door made of 1-3/4-inch solid core wood. The door must be hung in a fully stopped wood or steel frame and must be equipped with an automatic self-closing device and positive-latching hardware.

The heating plant door was not 1 ¾ inch solid core wood.

IV. RECOMMENDATION

An acceptable corrective action plan has been received. Renewal of the license is recommended.



_____10/14/2026

Regina Buchanan Date
Licensing Consultant